

# ABERDEEN FOAM TESTING SUMMARY



## A SUMMARY OF OUR INTERNATIONAL STANDARDS

FOAM CONCENTRATE	UL 162	ICAO Level B	ICAO Level C	EN 1568: 2018 Part 1	EN 1568: 2018 Part 2	EN 1568: 2018 Part 3	EN 1568: 2018 Part 4	LAST FIRE	IMO MSC.1/ Circ. 1312
1% AFFF-LF	✓	✓				✓			✓
3% AFFF-LF-C6	✓	✓				✓			
6% AFFF-LF		✓				✓			
1% AFFF-C6	✓								
3% AFFF-C6	✓	✓				✓			
6% AFFF-C6		✓							
3% AFFF-C6 AIRPORT FOAM		✓	✓						
1x1% AR-AFFF-C6						✓	✓		✓
1x3% AR-AFFF-C6						✓	✓		
3x3% AR-AFFF-C6	✓							✓	
1% F3-LF						✓			
1% F3						✓			
3% F3						✓			
3x3% AR-F3					✓	✓	✓		✓
2% HI-EX				✓	✓				✓
FRF				✓	✓				



### Oil Technics (Fire Fighting Products) Ltd.

Linton Business Park, Gourdon, Aberdeenshire, Scotland UK DD10 0NH

T: +44 (0) 1561 361515

E: [info@firefightingfoam.com](mailto:info@firefightingfoam.com)

W: [firefightingfoam.com](http://firefightingfoam.com)

All information correct at time of publication. Oil Technics (Fire Fighting Products) Ltd. reserve the right to modify any specification at any time and without prior notice.